

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Surge Protective Device
Name and address of the applicant	CITEL SAS 29 boulevard Edgar Quinet, 75014 Paris, France
Name and address of the manufacturer	CCSH Manufacturing Co., LTD. Building 2, No. 339 Xiupu Road, Pudong New Area, 201315 Shanghai, China
Name and address of the factory	CCSH Manufacturing Co., LTD. Building 2, No. 339 Xiupu Road, Pudong New Area, 201315 Shanghai, China
<i>When more than one factory</i>	<input type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	<b>Product data</b> Ratings: Test class II / Type 2 & Test class III / Type 3 Uc: 320 V~, In: 5 kA, I <sub>max</sub> : 10 kA, Uoc: 10 kV Up: 1.5 kV (L-N, L-PE), I <sub>sc</sub> : 10 kA, IL: 10 A, IP20
Trademark / Brand (if any)	CITEL
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	MLPC-VG1-230L-R, MLPC-VG1-230L-V, MLPC-VG2-230L-R and MLPC-VG2-230L-V
Additional information	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011  National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6213535.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
6825 MJ Arnhem  
Netherlands

Signature: B. Menzel



Date: 2025-09-17

Page 1 of 1