

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device

Name and address of the applicant

CITEL SAS
29 boulevard Edgar Quinet, 75014 Paris, France

Name and address of the manufacturer

CCSH Manufacturing Co., LTD.
Building 2, No. 339 Xiupu Road, Pudong New Area, 201315 Shanghai,
China

Name and address of the factory

CCSH Manufacturing Co., LTD.
Building 2, No. 339 Xiupu Road, Pudong New Area, 201315 Shanghai,
China*When more than one factory*☐ Additional information on page 2

Ratings and principal characteristics

Product data

Ratings:

Test class I/Type 1, Iimp: 12,5 kA;

Test class II/Type 2, In: 20 kA;

Test class III/Type 3, Uoc: 6 kV (Only for L-N);

Uc: 275 Vac (L-N) / 255 Vac (N-PE), Up: 1,5 kV, Imax: 50 kA;

Itotal(imp): 50 kA, Isccr: 50 kA, IP20

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

ZPAC1-13VG-30-275, ZPAC1-13VG-31-275, ZPAC1-13VG-PRO-M,
ZPAC1-13VG-PRO-S, ZPAC1-13VG-PRO-SM, ZPAC1-13VG-PRO-SU,
ZPAC1-13VG-PRO-SU-TNC, ZPAC1-13VG-PRO-SUM,
ZPAC1-13VG-PRO-U, ZPAC1-13VG-PRO-U-TNC and
ZPAC1-13VG-PRO-UM

Additional information

☐ Additional information on page 2A sample of the product was tested and
found to be in conformity with

IEC 61643-11:2011

National differences:

EU Group Differences

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-10-10


Signature: Massimiliano Triulzi



Ref. Certif. No.

NL-120529

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

As shown in the Test Report Ref. No.
which forms part of this Certificate

6139836.50 and 6234443.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-10-10

 
Signature: Massimiliano Triulzi