





Type 2 PV surge protector

CITEL

DS50PVS-1000/30



- ↳ Type 2 surge protector for PV
- ↳ In: 20kA / I_{max}: 40kA
- ↳ Pluggable
- ↳ Remote signaling
- ↳ UL 1449 ed.5 compliance
- ↳ IEC 61643-31, EN 61643-31, EN 50539-11 certified



V: High-energy varistor
 Ft: Thermal fuse
 t*: Thermal disconnection system
 MI: Disconnection indicator C: Remote signal contact

Electrical Characteristics		
SPD type		2
Network		PV network 1000 Vdc
Nominal PV voltage	Uocstc	1000 Vdc
Max. PV operating voltage	Ucpv	1300 Vdc
Residual Current	I _{pe}	< 0.1 mA
Leakage current to Ground		
PV Permanent Operating current	I _{cpv}	< 0.1 mA
Current consumption at Ucpv		
Follow current	I _f	None
Nominal discharge current	I _n	20 kA
15 x 8/20 μs impulses		
Max. discharge current	I _{max}	40 kA
max. withstand @ 8/20 μs by pole		
Total Maximum discharge current	I _{max Total}	60 kA
max. total withstand @ 8/20 μs		
Current withstand short circuit PV	I _{scpv}	15 000 A
Connection mode(s)		+/-/PE
Protection level	U _p	4.0 kV
@ I _n (8/20μs)		
Mechanical Characteristics		
Technology		MOV
Connection to Network		By screw terminals: 2.5-25mm ²
Operating temperature	T _u	-40/+85°C
Protection rating		IP20
Failsafe mode		Disconnection SPD of the PV line
Disconnection indicator		3 mechanical indicators
Remote signaling of disconnection		Output on changeover contact
Dimensions		See diagram
Disconnectors		
Thermal disconnector		Internal
Back-up protection device		Without
Standards		
Standards compliance		IEC 61643-31 / EN 61643-31 / EN 50539-11 / UL1449 ed.5
Certification		TUV Süd
Part number		
48031110		

