



Type 2 AC surge protector - Re-reinforced - pluggable

CITEL


DAC80S-31-275



- Re-reinforced Type 2 AC surge protector
- In: 40 kA
- Imax: 80 kA
- Pluggable module for each phase
- Remote signaling
- EN 61643-11, IEC 61643-11 certified
- UL1449 ed.5 compliance



	Electrical Characteristics	
	SPD type	2
	Network	230/400 V 3-phase+N
	AC system	TT-TNS
	Max. AC operating voltage	Uc 275 Vac
	Temporary Over Voltage (TOV) Characteristics - 5 sec. Without disconnection	UT 335 Vac withstand
	Temporary Over Voltage (TOV) Characteristics - 120 mn Without disconnection or with safety disconnection	UT 440 Vac disconnection
	Residual Current Leakage current to Ground	Ipe < 1 mA
	Follow current	If None
	Nominal discharge current 15 x 8/20 μs impulses	In 40 kA
	Max. discharge current max. withstand @ 8/20 μs by pole	Imax 80 kA
	Protection mode(s)	L/N and N/PE
	Protection level @ In (8/20μs) and @ 6 kV (1,2/50 μs)	Up L/N 1.6 kV
	Protection level N/PE @ In (8/20μs) and @ 6 kV (1,2/50 μs)	Up N/PE 1.5 kV
	Admissible short-circuit current	Iscrr 50 000 A
	Mechanical Characteristics	
	Technology	MOV+GDT
	Connection to Network	By screw terminals: 2.5-25mm ² (35mm ² rigid)
	Format	Plug-in modular box
	Mounting	Symmetrical rail 35 mm (EN 60715)
	Housing material	Thermoplastic UL94 V-0
	Operating temperature	Tu -40/+85°C
	Protection rating	IP20
	Failsafe mode	Disconnection from AC network
	Disconnection indicator	1 mechanical indicator by pole - Red/Green
	Spare module(s)	MDAC80-275
	Remote signaling of disconnection	Output on changeover contact
	Max. Voltage/Current for remote signaling	250 V / 0.5 A (AC) / 30 V / 3 A (DC)
	Dimensions	See diagram - 4TE (EN43880)
	Weight	0.419 kg
	Disconnectors	
	Thermal disconnector	Internal
	Installation ground fault breaker	Type 'S' or delayed
	Back-up protection device	Fuses Type gG - 125 A
	Standards	
	Standards compliance	IEC 61643-11 / EN 61643-11 / UL1449 ed.5
	Certification	KEMA
	Part number	
	821210244	



V: High-energy varistor
 GSG: Specific gas tube
 Ft: Thermal fuse
 C: Remote signaling contact
 †: Thermal disconnection system
 MI: Disconnection indicator

