




NEW CITEL PV SPD

- Type 2+3 surge protector for Photovoltaic
- CTC Technology
- Discharge currents I_{max}/I_{total} : 40/60 kA (8/20 μ s)
- Common/Differential mode protection
- Remote signaling
- IEC 61643-31, EN 61643-31, EN 50539-11, UL1449 ed.5 compliance
- Certified EN 61643-31 and IEC 61643-31



Electrical Characteristics		
SPD type	IEC	2+3
Network		PV 850 Vdc
Nominal PV voltage	Uocstc	710 Vdc
Max. PV operating voltage	Ucpv	850 Vdc
Residual Current Leakage current to Ground	Ipe	< 0.1 mA
PV Permanent Operating current Current consumption at Ucpv	Icpv	< 0.1 mA
Follow current	If	None
Nominal discharge current 15 x 8/20 μ s impulses	In	20 kA
Max. discharge current max. withstand @ 8/20 μ s by pole	I _{max}	40 kA
Withstand on Combination waveform IEC 61643-11 Class III test: 1.2/50 μ s - 8/20 μ s	Uoc	6 kV
Current withstand short circuit PV	Iscpv	15 000 A
Connection mode(s)		+/-/PE
Protection level +/- @ In (8/20 μ s)	Up	3.3 kV
Protection level +/-PE (-/PE) @ In (8/20 μ s)	Up	3,0 kV
Protection level at 5 kA @ 5 kA (8/20 μ s)	Up	2,6 kV
Protection level at Uoc @ Uoc (1.2/50 μ s)	Up	2,3 kV
Mechanical Characteristics		
Technology		MOV
Connection to Network		By screw terminals: 2.5-25mm ² (35mm ²) / by bus
Format		Compact monobloc box
Mounting		Symmetrical rail 35 mm (EN 60715)
Housing material		Thermoplastic UL94 V-0
Operating temperature	Tu	-40/+85°C
Protection rating		IP20
Failsafe mode		All pole disconnection from PV network
Disconnection indicator		1 mechanical indicator - Red/Green
Remote signaling of disconnection		Output on changeover contact
Dimensions		See diagram - 2.5TE (EN43880)
Disconnectors		
Thermal disconnector		CTC Technology integrated
Back-up protection device		Without
Standards		
Standards compliance		IEC 61643-31 / EN 61643-31 / EN 50539-11 / UL1449 ed.5
Certification		KEMA
Part number		65112104

